

GOVT. OF ASSAM
OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER (P.H.E.), TINSUKIA SUB DIVISION
TINSUKIA

No. APHEE/TSK/DLL-1/2019-20/.....119.....

Date: 04/02/2020

To
The Principal
Hindustani Kendriya Vidyalaya
Tinsukia

Sub:- Sanitation and Water Supply Certificate.

Ref:- HKV/TSK/OFF/F1/325/19-20, Dated 27/01/2020.

Respected Sir,

As per your request, I am to furnish herewith the certificate on Water Supply and Sanitation as found in field inspection.

This is for your kind information and necessary action.

Thanking you.

Yours Sincerely


Assistant Executive Engineer, PHED
Tinsukia Sub Division
Tinsukia



TO WHOM IT MAY CONCERN

As per request of the Principal, Hindustani Kendriya Vidyalaya, Tinsukia, the premises of the school have been visited for inspection of sanitation and water supply status. And it is found that -

- a) SANITATION :- There are adequate numbers of toilets and urinals for both Girls and Boys. All are found well maintained.
- b) Water Supply :- The school premises has one Deep Tube Well of 150 mm diameter and another shallow HTW. The Discharge of the DTW is sufficient to cater the demand of the students. A randomly selected water sample has been analysed and the results found as follows -

Turbidity	pH	Iron	TDS	Alkalinity	Chloride	Hardness	Fluoride	Bacteria
NTU		Mg/L	Mg/L	Mg/L	Mg/L	Mg/L	Mg/L	MPN/100 ml
5 - 10	6.5-8.5	0.3-1	500-1000	200-600	250-1000	300-600	1-1.5	
Nil	6.94	0.16	8.67	30	20	36	0.10	Nil

Assistant Executive Engineer, PHED
Tinsukia Sub Division

Tinsukia
Assst. Executive Engineer (PHE)
Tinsukia Sub-Division
TINSUKIA